

Reaction to fire

The applicant:

RENDERED TO EZOBORD BY OEM
RELATING EXCLUSIVELY TO EZOFELT BRANDED 2MM POLYESTER FELT

is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the report N° 2018AN2100



aitex
textile research institute

CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

N° 18AN2100

The sample reference:

RENDERED BY OEM MILL TO BE SOLD UNDER 'EZOFELT' BRAND

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2007+A1:2009 is:

“B-s1,d0”

Alcoy, July 27th 2018.



Firmado digitalmente
por CELIA[DOLÇA]
CAMAÑEZ
Fecha: 2018.07.27
12:21:40 +0200'

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.

